

# CERTIFICATE

**RE-L SIKRING IVS**  
Tinningvej 4  
8382 Hinnerup  
Denmark

Certifikat nr.  
Certificate no.  
**232.285**

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsescertifikat for systemet  
*has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and(or) other normative documents for the system*

**FCS - Detectomat**                      **Automatisk Branddetekterings- og Alarm-system**  
*Automatic Fire Detection and Alarm System*

til anvendelse i automatiske brandalarmanlæg.  
*to be used in automatic fire detection and alarm systems.*

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:  
*The certificate signifies compliance with the requirements in the following standards and other normative documents:*

EN 54-13:2005                      Fire detection and fire alarm systems – Part 13:  
Compatibility assessment of system components.

DBI Guideline 003                      Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.  
*The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.*

Udstedt/Issued: 2023-04-25  
Udløber/Expires: 2026-04-25  
Erstatter tidligere udstedt certifikat 2020-01-10  
*Replace previous issued certificate 2020-01-10*



Merete Poulsen



Steen Nilsson

Bilag/Annex: 1

## OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Control and indicating equipment	Dc3500 SL, FCP 3500 SL	0786-CPR-21428
Control and indicating equipment	Dc3500 ML, FCP 3500 ML	0786-CPR-21428
Accessories to the above	Loop module for fire control panel dc3500, protected, CP 3500 LOM P	
Accessories to the above	Fire Brigade module for dc3500, protected, CP FBM P	
Accessories to the above	Basic module for dc3500, protected, CP 3500 BBM P	
Accessories to the above	Printer module for dc3500, CP 3500 PRM	
Accessories to the above	Adapter for detect 3500, ADP 4000 for CON-X	
Input/output device	PL 3321 ECM	0786-CPR-21491
Power supply	Primary pulsed power supply, BF362-1	0786-CPR-20891
Power supply	Primary pulsed power supply, BF362-3	0786-CPR-21419
Power supply	Primary pulsed power supply, BF362-5	0786-CPR-20892
Smoke detector with isolator	PL 3300 O	0786-CPR-20035
Heat detector with isolator	PL 3300 T	0786-CPR-20044
Multi sensor detector (heat and smoke with isolator)	PL 3300 OTi Fusion	0786-CPR-20580
Multi sensor detector (heat and smoke with isolator)	PL 3300 OTi	0786-CPR-20578
Optical smoke detector using scattered light with isolator	PL 3305 O	0786-CPR-20041
Detector base to the above detectors	Detector base loop SDBB 3000	
Optical smoke detector using scattered light with isolator	PL 3301 O	0786-CPR-20037

Type Type	Produkt Product	Certifikat Certificate
Detector base to the above detectors	Detector base loop SDB 3000	
Addressable manual call point with isolator	PL 3300 PBDH	0786-CPD-20382 + DOP dated 23/02/2018
Addressable manual call point with isolator	PL 3300 MCP	0333-CPR-075280
Addressable manual call point	PL 3300 PBD-Alu-R B	0786-CPD-20382 + DOP dated 23/02/2018
Addressable input/output module with isolator	IOM 3311	0786-CPR-20459
Addressable input/output module with isolator	IOM 3322	0786-CPR-20459
Addressable input/output module with isolator	OMS 3301	0786-CPR-20459
Addressable input/output module with isolator	AMD 3311	0786-CPR-20530
Addressable input/output module with isolator	OMS 3301 mini	0786-CPR-20530
Addressable input/output module with isolator	PL 3321 ECM	0786-CPR-21491
Addressable input/output module with isolator	TCM 3300	0786-CPR-20373
Addressable input/output module	PCA 300s	0333-CPR-075548
Sounder with isolator	PL 3300 S 0 SE	0786-CPR-21279
Sounder with isolator	PL 3300 S 1 SE	0786-CPR-21279
Sounder	PL 3300w CONUS S	1438-CPR-0637
Sounder	PL 3300r CONUS S	1438-CPR-0637
Input/output device	Detector parallel indicator PA	0786-CPR-20804

Type Type	Produkt Product	Certifikat Certificate
Visual/acoustical alarm device	CT 3000 SF 0 SE	0786-CPR-21525
Visual/acoustical alarm device	CT 3000 SF 1 SE	0786-CPR-21525
Sounder	CT 3000 S 0 SE	0786-CPR-21268
Sounder	CT 3000 S 1 SE	0786-CPR-21268
Sounder	CS 200/SV	2831-CPR-F2409
Input/output device	Detector parallel indicator PA	0786-CPR-20804
Visual alarm device	ROLP LX WALL BASE	0333-CPR-75444
Line-type smoke detector	Fireray 3000	0786-CPR-21162
Line-type smoke detector	Fireray 5000	2831-CPR-F0390
Line-type smoke detector	Fireray One	2831-CPR-F2237
Aspirating smoke detector	Stratos Micra 100	2831-CPR-F1184
Aspirating smoke detector	Stratos Micra 25	2831-CPR-F1183

Bilag/Annex: 2

## PRØVNINGSdokUMENTATION TEST DOKUMENTATION

Akkediteret laboratorium <i>Accredited laboratory</i>	Rapport nr <i>Report no.</i>	Dato <i>Date</i>
VdS	Test Report No. 140869- AU01+BZA02-PB01	03-02-2016

Bilag/Annex: 3

## TEKNISK DOKUMENTATION TECHNICAL DOCUMENTATION

Titel <i>Name</i>	Reference <i>Refence</i>
Installation manual	Fire Control Panel dc3500 V3.4.x Installation manual 6.5.1. Password entry
Betjeningsvejledning	Brandcentral dc3500 V3.4.x Brugermanual
Kvikguide	Kvikguide til FCP dc3500 (V3.1.2)

Bilag/Annex: 4

## AFVIGELSER *DEVIANCE*

Not applicable for networked systems.