

CERTIFICATE

FAGTEK A/S
Brogesvej 18
7441 Bording
Denmark

Certifikat nr.
Certificate no.
232.302

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsescertifikat for systemet
has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and(or) other normative documents for the system

FAS Fire Alarm System

Automatisk Branddetekterings- og Alarm-system
Automatic Fire Detection and Alarm System

til anvendelse i automatiske brandalarmanlæg.
to be used in automatic fire detection and alarm systems.

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:
The certificate signifies compliance with the requirements in the following standards and other normative documents:

EN 54-13:2017+A1:2019 Fire detection and fire alarm systems – Part 13: Compatibility assessment of system components.

DBI Guideline 003 Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.
The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.

Udstedt/Issued: 2025-07-04
Udløber/Expires: 2028-07-04


Kenneth Maronie


Merete Poulsen

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Control Unit	FAS	1438-CPR-0520
Control Unit	FASmin	1438-CPR-0750
Smoke detector	S, SF	1438-CPR-0513
Heat detector	T, TF	1438-CPR-0512
Heat and Smoke detector	TS, TSF	1438-CPR-0511
Manual Call Point	ROP21 type A and B	1438-CPR-0510
Manual Call Point	ROP65	1438-CPR-0502
Duct smoke detector	DS	1438-CPR-0900
IN/OUT module	MIO 22/44/88	1438-CPR-0519
IN/OUT module	MIO 22n/44n	1438-CPR-0519
IN/OUT module	MIO 22LS	1438-CPR-0519
IN/OUT module	MIO 22CD	1438-CPR-0519
Loop adressable Sirens	LA, LA-D, LAP, LAP-D	1438-CPR-0904
Smoke Ventilation System Control	module SVS	1438-CPR-0831
Status indicator	WZ4	063-UWB-0432

Bilag/Annex: 2

PRØVNINGSdokUMENTATION TEST DOKUMENTATION

Akkrediteret laboratorium <i>Accredited laboratory</i>	Rapport nr <i>Report no.</i>	Dato <i>Date</i>
CNBOP	848/BA/25	2025-04-18

Bilag/Annex: 3

TEKNISK DOKUMENTATION TECHNICAL DOCUMENTATION

Titel <i>Name</i>	Reference <i>Reference</i>	Dato <i>Date</i>
SCHEME_EN_AWEX_evaluation		
Kort brugervejledning	BRIEF_UM_KORT BRUGER MANUAL FAS v25.0	Version 25.0
Kort brugervejledning	BRIEF_UM_KORT BRUGER MANUAL FASmini v25.0	Version 25.0
Brugervejledning	FAS brandalarmsystem -kontrolenhed-	Version 25.0
Brugervejledning	FASmini brandalarmsystem -kontrolenhed-	Version 25.0
Configuraion manual	FAS Fire alarm system	Version 25.0
Instruktion til deaktivering	DISABLING_BRIEF_M_FRAKOBLE MANUAL FASmini v25.0	Version 25.0

Bilag/Annex: 4

AFVIGELSER DEVIANCE

Intet.
None.