

CERTIFICATE

Securiton AG
Alpenstrasse 20
CH-3052 Zollikofen
Switzerland

Certifikat nr.
Certificate no.

232.278

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsescertifikat for systemet
has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and(or) other normative documents for the system

SecuriFire FCP 500

Automatisk Branddetekterings- og Alarm-system
Automatic Fire Detection and Alarm System

til anvendelse i automatiske brandalarmanlæg.
to be used in automatic fire detection and alarm systems.


Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:
The certificate signifies compliance with the requirements in the following standards and other normative documents:

EN 54-13:2005 Fire detection and fire alarm systems – Part 13:
Compatibility assessment of system components.

DBI Guideline 003 Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.
The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.

Udstedt/Issued: 2025-03-31
Udløber/Expires: 2028-03-31
Erstatter tidligere udstedt certifikat 2021-12-16
Replace previous issued certificate 2021-12-16



Kenneth Maronie



Merete Poulsen

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Control and indicating equipment with power supply equipment	SecuriFire FCP 500	0786-CPR-21185
In -/Output Devices with short-circuit isolator	BX-OI3	0786-CPD-21011 and DOP CPR-20-13-005
In -/Output Devices with short-circuit isolator	BX-O2I4	0786-CPD-21066 and DOP CPR-20-20-012
In -/Output Devices with short-circuit isolator	BX-O2I4-HP	0786-CPR-21066 and DOP CPR-20-20-012
In -/Output Devices with short-circuit isolator	BX-IOM	0786-CPD-21010 and DOP CPR-20-13-006
Input Devices with short-circuit isolator	BX-REL4	0786-CPD-21012 and DOP CPR-20-13-008
In -/Output Devices with short-circuit isolator	BX-IM4	0786-CPD-21009 and DOP CPR-20-13-007
In -/Output Devices with short-circuit isolator	BX-AIM, Detachable and Software controlled I/O with integrated SCI	0786-CPR-20601 and DOP CPR-20-13-009
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with short circuit isolator	CCD 573X, addressable	0786-CPR-21215
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with short circuit isolator	CCD 573X MC, addressable	0786-CPR-21215
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with short circuit isolator	MCD 573X, addressable	0786-CPR-21020
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with short circuit isolator	MCD 573X CP, addressable	0786-CPR-21020
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with short circuit isolator	MCD 573X MC, addressable	0786-CPR-21020
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with short circuit isolator	MMD 130 Ex-i	0786-CPR-21104

Type Type	Produkt Product	Certifikat Certificate
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with integrated sounder and short circuit isolator	MCD 573X-S, Software controlled I/O with integrated SCI	0786-CPR-21278
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with integrated sounder and short circuit isolator	MCD 573X-S MC, Software controlled I/O with integrated SCI	0786-CPR-21278
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with integrated sounder and short circuit isolator	MCD 573X-SP, Software controlled I/O with integrated SCI	0786-CPR-21278
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with integrated sounder and short circuit isolator	MCD 573X-SP MC, Software controlled I/O with integrated SCI	0786-CPR-21278
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with integrated sounder and short circuit isolator	MCD 573X-SP EE, Software controlled I/O with integrated SCI	0786-CPR-21278
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with integrated sounder and short circuit isolator	MCD 573X-SP AE, Software controlled I/O with integrated SCI	0786-CPR-21278
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with integrated sounder and short circuit isolator	MCD 573X-SCT, Software controlled I/O with integrated SCI	0786-CPR-21278
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with integrated sounder and short circuit isolator	MCD 573X-SCT MC, Software controlled I/O with integrated SCI	0786-CPR-21278

Type Type	Produkt Product	Certifikat Certificate
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with integrated sounder and short circuit isolator	MCD 573X-SPCT, Software controlled I/O with integrated SCI	0786-CPR-21278
Heat and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with integrated sounder and short circuit isolator	MCD 573X-SPCT MC, Software controlled I/O with integrated SCI	0786-CPR-21278
Manual call point with integrated short-circuit isolator	MCP 545X-N	0786-CPR-20998
Manual call point with integrated short-circuit isolator	MCP 545X-1 N	0786-CPR-20998
Manual call point with integrated short-circuit isolator	MCP 545X-2 N	0786-CPR-20998
Manual call point with integrated short-circuit isolator	MCP 545X-1A N	0786-CPR-20998
Manual call point with integrated short-circuit isolator	MCP 545X-1S N	0786-CPR-20998
Manual call point with integrated short-circuit isolator	MCP 545X-4 N	0786-CPR-20998
Sounder with integrated short-circuit isolator	BX-SOL-R (red)	0786-CPR-20986
Sounder with integrated short-circuit isolator	BX-SOL-W (white)	0786-CPR-20986
Sounder with integrated short-circuit isolator	BX-SOL-CT, with Software controlled SCI	0786-CPR-20986
Sounder with integrated short-circuit isolator	BX-SBL501-W (white)	0786-CPR-21065
Sounder with integrated short-circuit isolator	BX-SBL501-WDB (white, sidewise cable installation)	0786-CPR-21065
Sounder with integrated short-circuit isolator	BX-SBL502-W (white)	0786-CPR-21065
Sounder with integrated short-circuit isolator	BX-SBL502-WDB (white, sidewise cable installation)	0786-CPR-21065
Sounder with integrated short-circuit isolator	BX-SBL502-RDB	0786-CPR-21065
Optical alarm device with integrated short-circuit isolator	BX-FOL-RR (red base, red light)	0786-CPR-20987
Optical alarm device with integrated short-circuit isolator	BX-FOL-WR (white base, red light)	0786-CPR-20987
Optical alarm device with integrated short-circuit isolator	BX-FOL-RO (red base, orange light)	0786-CPR-20987

Type Type	Produkt Product	Certifikat Certificate
Optical alarm device with integrated short-circuit isolator	BX-FOL-WO (white base, orange light)	0786-CPR-20987
Duct smoke detector with short-circuit isolator	LKM 593X	0786-CPR-21413
Aspirating smoke detectors with short-circuit isolator	ASD 535-1, with detachable SCI. Only via I/O BX-OI3	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator	ASD 535-1 SE, with detachable SCI. Only via I/O BX-OI3	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator	ASD 535-2, with detachable SCI. Only via I/O BX-OI3	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator	ASD 535-2 SE, with detachable SCI. Only via I/O BX-OI3	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator	ASD 535-3, with detachable SCI. Only via I/O BX-OI3	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator	ASD 535-3 SE, with detachable SCI. Only via I/O BX-OI3	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator	ASD 535-4, with detachable SCI. Only via I/O BX-OI3	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator	ASD 535-4 SE, with detachable SCI. Only via I/O BX-OI3	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator	ASD 533-1, with detachable SCI.	0786-CPR-21207
Aspirating smoke detectors with short-circuit isolator	ASD 531, with detachable SCI.	0786-CPR-21482
Aspirating smoke detectors with short-circuit isolator	ASD 532, with detachable SCI.	0786-CPR-21483
Smoke detectors - Line detectors - Line detectors using an optical beam	BSD 535	1116-CPR-100-3
Smoke detector with short-circuit isolator	ILIA ERHS0712, without reflector, with integrated SCI	0786-CPR-20925
Smoke detector with short-circuit isolator	ILIA ERRHS0712, with integrated SCI	0786-CPR-20925
Line-type Heat Detector ONLY EMC tested	LIST	Only tested for EMC EN 50130-4:2011 test report no. 120502-AU01+UCE01
Line-type Heat Detector ONLY EMC tested	d-LIST	Only tested for EMC EN 50130-4:2011 test report no. BMA 05129
Line-type Heat Detector ONLY EMC tested	ADW 535-1 Only via I/O BX-OI3	Only tested for EMC EN 50130-4:2011 test report no. 122547-AU01-UC EE01-PB01 and 172317-AU11+BZA01-PB02

Type <i>Type</i>	Produkt <i>Product</i>	Certifikat <i>Certificate</i>
Line-type Heat Detector ONLY EMC tested	ADW 535-2 Only via I/O BX-OI3	Only tested for EMC EN 50130-4:2011 test report no. 122547-AU01-UC EE01-PB01 and 172317-AU11+BZA01-PB02
Line-type Heat Detector ONLY EMC tested	ADW 535-1HDx Only via I/O BX-OI3	Only tested for EMC EN 50130-4:2011 test report no. 122547-AU01-UC EE01-PB01, 172317- AU11+BZA01-PB02 and 142341- AU01+UC EE01-PB01
Line-type Heat Detector ONLY EMC tested	ADW 535-2HDx Only via I/O BX-OI3	Only tested for EMC EN 50130-4:2011 test report no. 122547-AU01-UC EE01-PB01, 172317- AU11+BZA01-PB02 and 142341- AU01+UC EE01-PB01

Bilag/Annex: 2

PRØVNINGSdokUMENTATION TEST DOKUMENTATION

Akkrediteret laboratorium <i>Accredited laboratory</i>	Rapport nr <i>Report no.</i>	Dato <i>Date</i>
VdS Schadenverhütung GmbH	BMA 14090	2014-09-03
VdS Schadenverhütung GmbH	172317-AU12+BZA01-PB01	2020-10-07

Bilag/Annex: 3

TEKNISK DOKUMENTATION *TECHNICAL DOCUMENTATION*

Titel Name	Reference Refence	Dato Date
Mounting and Installation	T 811 065 en I	2024.05.09
SecuriFire BDS Kort betjeningsvejledning via MIC	T811047 da	2017-04-21
Vedligeholdelse og reparation/ Maintenance and Service	T811 091 da h/ T 811 091 en h	2021-05-28 2021-05-28
SecuriFire MIC Operating instructions	T811 083 en h	2020-01-15

Bilag/Annex: 4

AFVIGELSER *DEVIANCE*

- The system can not be used as networked systems.
- The system can not be used in a hierarchical systems.