

CERTIFICATE

Schneider Electric Danmark A/S
Lautrupvang 1
2750 Ballerup
Denmark

Certifikat nr.
Certificate no.
232.283

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsescertifikat for systemet
has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and(or) other normative documents for the system

FDP **Automatisk Branddetekterings- og Alarm-system**
Automatic Fire Detection and Alarm System

til anvendelse i automatiske brandalarmanlæg.
to be used in automatic fire detection and alarm systems.

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:
The certificate signifies compliance with the requirements in the following standards and other normative documents:


EN 54-13:2017 Fire detection and fire alarm systems – Part 13: Compatibility assessment of system components.

DBI Guideline 003 Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.
The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.

Udstedt/Issued: 2026-04-10
Udløber/Expires: 2029-04-10
Erstatter tidligere udstedt certifikat 2023/03/29
Replace previous issued certificate 2023/03/29


Kenneth Maronie


Andrew Marc

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Control and indicating equipment	FDP221	0402-CPR-SC0154-17
Control and indicating equipment	FDP252	0402-CPR-SC0154-17
Control and indicating equipment	FDP292	0402-CPR-SC0154-17
Power supply equipment	FDP221	0402-CPR-SC0155-17
Power supply equipment	FDP252	0402-CPR-SC0155-17
Power supply equipment	FDP292	0402-CPR-SC0155-17
Smoke point detector with integrated light	P/N 55000-268	0786-CPD-20313 and DOP 0786-CPD-20313
Smoke point detector with integrated light	P/N 5500-273	0786-CPD-20313 and DOP 0786-CPD-20313
Smoke point detector	EDI-20	2531-CPR-CSP10943
Sounder with integrated visual alarm device and short circuit isolator	45681-705	2531-CPR-CSP11167
Manual call point with short circuit isolator	EPP-20 ESMI Intellia Manual call point with short circuit isolator	2531-CPR-CSP11016
Manual call point with shortcircuit isolator	EPP-22A ESMI Intellia Waterproof Manual call point with isolator	0905-CPR-00247
Visual alarm device with short circuit isolator	45681-709 XP95	2531-CPR-CSP11169
CO Heat point detector	CO Heat Multisensor 58000-305APO	2531-CPR-CSP10932
Short-circuit isolator.	EMI-400 DIN-Rail Dual isolator	2531-CPR-CSP11072
In -/Output Devices with short-circuit isolator.	EMI-410/CZ DIN-Rail Conventional Zone Monitor with isolator	2531-CPR-CSP11073
Smoke and Heat point detector	EDI-30 ESMI Intellia Multisensor Smoke Detector	2531-CPR-CSP10947
Heat point detector	EDI-50 ESMI Intellia Heat Detector	2531-CPR-CSP10935
Sounder device	ESI-10 ESMI Intellia Ancillary Base Sounder	2531-CPR-CSP11094
Sounders device with short circuit isolator	ESI-60 ESMI Intellia Sounder Visual Indicator Base with isolator	2531-CPR-CSP11182

Sounder device	ESI-30 ESMI Intellia Integrated Base Sounder	2531-CPR-CSP11107
Sounders device with short circuit isolator	ESI-20 ESMI Intellia Base Sounder with isolator	2531-CPR-CSP11096
In -/Output device	55000-855 XP95 Analogue Addressable DIN-Rail Protocol Translator	2531-CPR-CSP11047
Smoke point detector	55000-640 XP95 Analogue Addressable Intrinsically Safe Optical Smoke detector	2531-CPR-CSP10929
Heat point detector	55000-440 Analogue Addressable Intrinsically Safe Class A2S XP95 heat detector	2531-CPR-CSP10920
Manual call point	55100-940 XP95 Analogue Addressable Intrinsically Safe manual call point	2531-CPR-CSP11014
Sounder device with short circuit isolator	55000-298 Addressable Type B Weatherproof sounder	2531-CPR-CSP11138
Manual call point with short circuit isolator	FFS06723706 Intelligent Addressable Manual Call Point with Short Circuit Isolator	2531-CPR-CSP11024
Manual call point with short circuit isolator	ECE221-I ESMI Essentia Manual Call point with short circuit isolator	2531-CPR-CSP11030
Manual call point with short circuit isolator	EPP-21 ESMI Intellia Manual Call Point	2531-CPR-CSP11016
Manual call point with short circuit isolator	EPP-20 ESMI Intellia Manual Call Point	2531-CPR-CSP11016
Sounder device	55000-274 Multi tone weatherproof Type B Sounder	2531-CPR-CSP11134
In -/Output Devices with short-circuit isolator.	5500-760 Analogue Addressable mini switch monitor	2531-CPR-CSP11042
In -/Output Devices with short-circuit isolator.	EMI-301/S ESMI Intellia Sounder Control Module	2531-CPR-CSP11075
In -/Output Devices with short-circuit isolator.	EMI-310/CZ ESMI Intellia Conventional Zone Module	2531-CPR-CSP11074
In-/Output device with short circuit isolator and Radio links	XPA-IN-1450-APO Xpander Loop interface with Diversity with Wire Aerials	0905-CPR-00223
In-/Output device with short circuit isolator and Radio links	XPA-IN-1451-APO Xpander Loop interface with Diversity with SMA Aerials	0905-CPR-00223
Flame point detector	5500-280 Analogue Adressable IR2 Flame dectector, Class 1 only	2831-CPR-F0595
Visual alarm device	55000-741 Loop-Powered Type A VAD 6m (RED)	2831-CPR-F0607

Visual alarm device	55000-742 Loop-Powered Type A VAD 8.5m (RED)	2831-CPR-F0608
Flame point detector	55000-022 Intelligent UV Flame detector, Class 1 and 3	2831-CPR-F0354
Flame point detector	55000-023 XP95 Intelligent UV/IR2 Flame detector, Class 1 and 3	2831-CPR-F0355
Flame point detector	55000-024 XP95 Intelligent IR3 Flame detector, Class 1 and 3	2831-CPR-F0356
Heat point detector with short circuit isolator	EDE221-I ESMI Essentia Heat Detector	2531-CPR-CSP10981
Smoke point detector with short circuit isolator	EDE222-I ESMI Essentia Optical Smoke Detector	2531-CPR-CSP10985
Smoke and Heat point detector with short circuit isolator	EDE223-I ESMI Essentia Smoke/Heat Multi Detector	2531-CPR-CSP10989
In -/Output Devices with short-circuit isolator.	EME210-I ESMI Essential Switch Monitor	2531-CPR-CSP11077
In -/Output Devices with short-circuit isolator.	EME212-I ESMI Essential Input/Output Unit	2531-CPR-CSP11077
In -/Output Devices with short-circuit isolator.	EME213-I ESMI Essential DIN-Rail I/O Unit	2531-CPR-CSP11077
In -/Output Devices with short-circuit isolator.	EME214-I ESMI Essential DIN-Rail Switch Monitor	2531-CPR-CSP11077
In -/Output Devices with short-circuit isolator.	EME215-I ESMI Essential Main Switching I/O Unit	2531-CPR-CSP11082
In -/Output Devices with short-circuit isolator.	EME211-I ESMI Essential Twin Switch Monitor	2531-CPR-CSP11088
In -/Output Devices with short-circuit isolator.	EME216-I ESMI Essential Twin input/Output Unit	2531-CPR-CSP11088
Smoke and Heat point detector with short circuit isolator	ESMI22051TLEI Multi sensor detector with short circuit isolator	0786-CPR-20697
Smoke and Heat point detector with short circuit isolator	ESMI22051TEI Multi sensor detector with short circuit isolator	0786-CPR-20698
Smoke point detector with short circuit isolator	ESMI22051EI Multi sensor detector with short circuit isolator	0786-CPR-20699
Heat point detector with short circuit isolator	ESMI52051EI Static Heat detector with short circuit isolator	0786-CPD-20700 and DOP-IFD185
Heat point detector with short circuit isolator	ESMI52051HTEI Static Heat detector with short circuit isolator	0786-CPD-20701 and DOP-IFD187
Heat point detector with short circuit isolator	ESMI52051REI Rate of Rise Heat detector with short circuit isolator	0786-CPD-20702 and DOP-IFD183
Smoke and Heat point detector	ESMI22051TLE Multi sensor detector	0786-CPR-20703
Smoke and Heat point detector	ESMI22051TE Multi sensor detector	0786-CPR-20704

Smoke point detector using scattered light, transmitted light or ionization	ESMI22051E Optical smoke detector using scattered light	0786-CPR-20705
Heat point detector	ESMI52051E Static Heat detector	0786-CPD-20706 and DOP-IFD176
Heat point detector	ESMI52051HTE Static Heat detector	0786-CPD-20707 and DOP-IFD186
Heat point detector	ESMI52051RE Rate of Rise Heat detector	0786-CPD-20708 and DOP-IFD182
Heat point detector. Smoke point detector using scattered light, transmitted light or ionization	ESMI2251CTLE-yy Analogue Addressable Multi-Criteria detector	2831-CPR-F1325
In -/Output Devices with short-circuit isolator.	M220E	0786-CPR-21655
In -/Output Devices with short-circuit isolator.	M210E	0786-CPR-21655
In -/Output Devices with short-circuit isolator.	M201E	0786-CPR-21660
In -/Output Devices with short-circuit isolator.	M201E-240	0786-CPR-21660
In -/Output Devices with short-circuit isolator.	M221E	0786-CPR-21650
Sounders device with short circuit isolator	BSO-xx-lyy Analogue addressable Type A integrated base sounder with short circuit isolator	2831-CPR-F1953
Sounders device	BSO-xx-Nyy Analogue addressable Type A integrated base sounder	2831-CPR-F1949
Sounders device with short circuit isolator	BSS-xx-lyy Analogue addressable Type A integrated base sounder/strobe with short circuit isolator	2831-CPR-F1954
Sounders device	BSS-xx-Nyy Analogue addressable Type A integrated base sounder/strobe	2831-CPR-F1950
Sounders device	WSO-xx-Nyy Analogue addressable Type A/B wall mounted sounder	2831-CPR-F1947
Sounders device with short circuit isolator	WSO-xx-lyy Analogue addressable Type A/B wall mounted sounder with short circuit isolator	2831-CPR-F1951
Smoke point detector	ED2351E Conventional Optical Smoke Detector	2831-CPR-F1320
Smoke and Heat point detector	ED2351TEM Conventional Class A1R Photo/thermal Detector	2831-CPR-F1324
Heat point detector	ED5351E Conventional Class A1R rate of rise heat detector	2831-CPR-F1321

Manual call point with short circuit isolator	MCP5A-RPwwwx-yyyy-zz Indoor Addressable Call point with short circuit isolator	2831-CPR-F1735
Sounders device with short circuit isolator	WSS-PR-I333 Analogue addressable sounder with short circuit isolator	2831-CPR-F1952
Smoke point detector using scattered light, transmitted light or ionization	22051EISE Intrinsically Safe Analogue Addressable Photoelectric Smoke Detector	2831-CPR-F1956
Manual call point with short circuit isolator	WCP5A-RPwwSx-yyyy-zz Outdoor Surface addressable Waterproof call point with short circuit isolator	2831-CPR-F1737
Manual call point with isolator	MCP5A-RPwwSx-yyyy-zz Indoor Surface addressable call point with isolator	2831-CPR-F1735
Manual call point	MCP1A-Rxxxxx-yyyy-zz Indoor Surface/Flush Mounting Conventional call point	2831-CPR-F1701
Smoke point detector with short circuit isolator	72051EI High Sensitivity Point Optical Smoke Detector with Isolator	2831-CPR-F2556
In-/output device using radio links with isolator	M200G-RF-xx	0333-CPR-075484
Sounder with visual alarm device	DSS-PC-I33 Base beacon sounder	2831-CPR-F2086
Sounder with visual alarm device	DSS-PC-N33 Base beacon sounder	2831-CPR-F2086
Short circuit isolator with visual alarm	WST-PC-I33 VAD Isolator	2831-CPR-F0270
Visual alarm device	WST-PC-N33 VAD NON-ISO	2831-CPR-F0273
In-/Output device using radio links	M200F-RF	0333-CPR-075501
Manual call point using radio links	R5A-RF	0333-CPR-075496
Smoke point detector using radio links	ESMI22051E-RF radio Optical smoke Sensor	0333-CPR-075561
Point heat and smoke detector using radio links	ESMI22051TLE-RF multi criteria fire sensor	0333-CPR-075487
Point heat detector using radio links	52051E-RF Wireless Fixed 58C Thermal Fire Sensor	0333-CPR-075490
Point heat detector using radio links	52051RE-RF Wireless rate-Of-Rise Thermal Fire Sensor	0333-CPR-075493
Sounder using radio links	WSO-RR-RF Radio Sounder	0905-CPR-00819
Sounder using radio links	WSO-WW-RF Radio Sounder	0905-CPR-00819

In-/Output module using radio links	XPA-IN-14011-APO Single Input/Output Unit	0905-CPR-00035
In-/output device using radio links	XPA-IN-14012-APO Dual Input/Output Unit	0905-CPR-00035
Smoke point detector with isolator	FL5100-600 Soteria Dimension Optical Detector	2531-CPR-CSP10950
Smoke point detector with isolator	FL6100-600 Soteria Dimension Specialist Optical Detector	2531-CPR-CSP10952
Visual alarm device	55000-743 Loop-Powered Type A VAD 15 m (White)	2831-CPR-F0609
Visual alarm device	55000-744 Loop-Powered Type A VAD 6 m (White)	2831-CPR-F0610
Visual alarm device	55000-745 Loop-Powered Type A VAD 8.5 m (White)	2831-CPR-F0611
Smoke detector with isolator	ESMI Impresia Smoke Detector FFS06741001	1293-CPR-0771
Heat detector with isolator	Esmi Impresia Heat Detector FFS06741002 Esmi Impresia Black Heat detector EIB-120	1293-CPR-0878
Heat and smoke detector with isolator	Esmi Impresia Multicriteria Detector FFS06741003 Esmi Impresia Black Multicriteria Detector EIB-1300	1293-CPR-0878
Manual call point with isolator	Esmi Impresia Manual Call Point FFS06741004	1293-CPR-0774
Manual call point with isolator	Esmi Impresia IP67 Manual Call Point FFS06741005	1293-CPR-0775
In-/output with isolator	Esmi Impresia Zone Module FFS06741006	1293-CPR-0776
In-/output with isolator	Esmi Impresia 2 Inputs/2 Outputs Module FFS06741007	1293-CPR-0777
In-/output with isolator	Esmi Impresia 2 Inputs/2 Monitored Outputs Module FFS06741008	1293-CPR-0778
In-/output with isolator	Esmi Impresia 0 Inputs/4 Outputs Module FFS06741009	1239-CPR-0779
In-/output with isolator	Esmi Impresia 4 Inputs/0 Outputs Module FFS06741010	1293-CPR-0780
Sounder with isolator	Esmi Impresia Red Wall Mounted Sounder FFS06741011	1293-CPR-0783
Sounder with isolator	Esmi Impresia White Wall Mounted Sounder FFS06741014	1293-CPR-0783
Sounder beacon with isolator	Esmi Impresia Red VAD Wall Mounted Sounder FFS06741012	1293-CPR-0784
Sounder beacon with isolator	Esmi Impresia White VAD Wall Mounted Sounder FFS06741015	1293-CPR-0784

Sounder with isolator	Esmi Impresia Base with Sounder FFS06741016	1293-CPR-0785
Sounder with isolator	Esmi Impresia Base with Sounder Beacon FFS06741017	1293-CPR-0786
In-/Output with isolator	Esmi Impresia Potential Output for Sounder Module FFS06741019	1293-CPR-0782
In-/Output with isolator	Esmi Impresia Relay Output Module 240V FFS06741020	1293-CPR-0781
Sounder with isolator	Esmi Impresia Base Base Sounder, FFS06741030 Esmi Impresia Black Base Sounder EIB-6200	1293-CPR-0893
Sounder beacon with isolator	Esmi Impresia Base Sounder Beacon, FFS06741031	1293-CPR-0894
Sounder beacon with isolator	Esmi Impresia R VAD for Base Sounders, FFS06741032	1293-CPR-0895
Sounder beacon with isolator	Esmi Impresia W VAD for Base Base Sounders, FFS06741033	1293-CPR-0895
Smoke beam detector with isolator	EB6500E Intelligent Beam Detector	1293-CPR-0751
Smoke beam detector with isolator	EB6500SE Intelligent Beam Detector	1293-CPR-0751
Sounder with visual alarm device and short circuit isolator	BRH-PC-I33 Addressable Type A Detector Base Sounder	2831-CPR-F4461
Sounder with visual alarm device and short circuit isolator	BRS-PC-I33 Addressable Type A Detector Base Sounder Strobe	2831-CPR-F4464
In-/Output with isolator	EM201EA single channel output module	0905-CPR-210493
In-/Output with isolator	EM210EA single channel input module	0905-CPR-210493
In-/Output with isolator	EM220EA dual channel input module	0905-CPR-210493
In-/Output with isolator	EM221EA dual channel input, single channel output module	0905-CPR-210493
Smoke detector – Line detector using an optical beam with short-circuit isolator	SA7100-100APO Adressable Beam Detector with Automatic Alignment	2531-CPR-CSP11008
Wireless components only with In-/Output device XPA-IN-1451-APO		
Smoke point detector using scattered light, transmitted light or ionization	XPA-OP-12034-APO Photoelectric Smoke detector only with MN1500 LR6-1.5 volt alkaline AA battery	0905-CPR-00681 & 0905-CPR-00037
Heat point detector	XPA-HT-11170-APO Heat detector only with MN1500 LR6-1.5 volt alkaline AA battery	0905-CPR-00695 & 0905-CPR-00037

Heat point detector	XPA-HT-11171-APO Heat detector only with MN1500 LR6-1.5 volt alkaline AA battery	0905-CPR-00695 & 0905-CPR-00037
Components using radio links	Xpander Wireless Detector Bases	0905-CPR-00037
Manual call point	XPA-MC-14006-APO Xpander Manual Call Point	0905-CPR-00033

Bilag/Annex: 2

PRØVNINGS DOKUMENTATION

TEST DOKUMENTATION

Akkediteret laboratorium <i>Accredited laboratory</i>	Rapport nr. <i>Report no.</i>	Dato <i>Date</i>
RISE	9P02928-3	2019-12-02
RISE	P109712.DP06.A01	2022-02-11
RISE	P109712-2	2021-10-25
RISE	7P08846-1 Rev.1	2018-10-23
RISE	9P02928-1	2019-08-16
ANPI	BFS/DE/S/007 Add.10	2018-11-07
ANPI	BFS/DE/S/007 Add.11	2019-07-02
ANPI	BFS/DE/S/032	2013-10-04
ANPI	Addendum no. 1 to BFS/DE/S/032	2013-12-02
DELTA	A530858-1	2011-08-31
RISE	P116411.DP01.A01 Rev1	2023-01-25
RISE	P124774.DP01.A01	2025-04-14

Bilag/Annex: 3

TEKNISK DOKUMENTATION TECHNICAL DOCUMENTATION

Titel Name	Reference Refence	Dato Date
Installation Quick Guide	O2086GB3, RevC	2024-07
Installation Quick Guide	O2087GB4, RevC	2024-07
Installation Quick Guide	O2088GB1, RevB	2024-02
Installation Quick Guide	O2089GB1, RevB	2024-02
Simpel betjeningsvejledning	O1884DK9 FDP-brandcentral User manual DK	2025-02
Betjeningsvejledning	O1884DK9 FDP-Brandcentral	2025-02
Installation and Commissioning Manua	O1885GB18 FDP Fire Detection Panel	2025-05

Bilag/Annex: 4

AFVIGELSER DEVIANCE

Intet.
None.