

CERTIFICATE

Panasonic Fire & Security Europe AB
Jungmansgatan 12
SE-211 11 Malmö
Sweden

Certifikat nr.
Certificate no.
232.301

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsescertifikat for systemet
has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and(or) other normative documents for the system

EBLone type 2000 system **Automatisk Branddetekterings- og Alarm-system**
Automatic Fire Detection and Alarm System

til anvendelse i automatiske brandalarmanlæg.
to be used in automatic fire detection and alarm systems.

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:
The certificate signifies compliance with the requirements in the following standards and other normative documents:

EN 54-13:2017+A1:2019 Fire detection and fire alarm systems –
Part 13: Compatibility assessment of system components.

DBI Guideline 003 Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.
The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.

Udstedt/Issued: 2025-03-14
Udløber/Expires: 2028-03-14



Kenneth Maronie



Merete Poulsen

Bilag/Annex: 1

OMFANG/*EXTENT*

Type <i>Type</i>	Produkt <i>Product</i>	Certifikat <i>Certificate</i>
EBLOne Type 2000	Control and indicating equipment with power supply	0402-CPR-C500347 0402-CPR-C500348
4401	Optical smoke detector scattered light type	0786-CPR-21175
4400	Multi sensor detector	0786-CPR-21172
4433	Manual call point	0786-CPR-21235
4439	Manual call point	0786-CPR-21236
4400I	Multi sensor detector	0786-CPR-21553
4479	Sounder	0786-CPR-21564
4480	Visual Alarm Device	0786-CPR-21531
4481	Visual Alarm Device	0786-CPR-21532
4482	Visual/Acoustical Alarm Device	0786-CPR-21533
4487	Sounder	0786-CPR-21534
4461	Input-/Output Device	0786-CPR-21579
4462	Input-/Output Device	0786-CPR-21589
ASPECT 2010-Series	Aspirating Smoke Detector	0786-CPR-21084
4401I	Smoke Detector	0786-CPR-21673
4466	Power Supply Equipment	0786-CPR-21627
4408	Heat Detector	0786-CPR-21763
4409	Heat Detector	0786-CPR-21764
3379	Sounder	0786-CPR-20954
4460 (230 VAC relay output unit)	Input-/Output Device	0402-CPR-C500371 0402-CPR-C500372
4381	Visual alarm Device	1438-CPR-0886
4620	Input-/Output Device	0786-CPR-21393
4611	Optical smoke detector scattered light type	0786-CPR-21392
4614	Wireless manual call point	0786-CPR-21613

Bilag/Annex: 2

PRØVNINGS DOKUMENTATION

TEST DOCUMENTATION

Akkrediteret laboratorium <i>Accredited laboratory</i>	Rapport nr <i>Report no.</i>	Dato <i>Date</i>
VdS Schadenverhütung GmbH	231494-AU01+BZA02-PB01	2024-10-25
VdS Schadenverhütung GmbH	231494-AU01+BMA02-PB01	2024-10-25
VdS Schadenverhütung GmbH	231494-AU02+SPB01-PB01	2024-06-04
RISE Research Institutes of Sweden AB	P115907.DP01.A01-1	2023-06-05

Bilag/Annex: 3

TEKNISK DOKUMENTATION

TECHNICAL DOCUMENTATION

Titel <i>Name</i>	Reference <i>Refence</i>
Mounting instructions, 2000	MEW02873
Planlægningsinstruktioner	MEW02993
Daglig Brugers Manual	MEW02823 – Rev. 1

Bilag/Annex: 4

AFVIGELSER

DEVIANCE

Intet.
None.