

CERTIFICATE

SV Sistemi di Sicurezza Srl
Via Matteotti, 55/57
IT-24050 Grassobbio (Bergamo)

Certifikat nr.
Certificate no.
232.290

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsecertifikat for systemet
has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and(or) other normative documents for the system

EXFIRE360/Autrosafe

Automatisk Branddetekterings- og Alarm-system
Automatic Fire Detection and Alarm System

til anvendelse i automatiske brandalarmanlæg.
to be used in automatic fire detection and alarm systems.

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:
The certificate signifies compliance with the requirements in the following standards and other normative documents:

EN 54-13:2017 Fire detection and fire alarm systems – Part 13:
Compatibility assessment of system components.

DBI Guideline 003 Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.
The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.

Udstedt / Issued: 2021-07-09

Udløber/expire: 2024-07-09

Erstatter tidligere udstedt certifikat
Replace previous issued certificate



Allan Laursen



Merete Poulsen

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Control and indicating equipment with Power supply equipment	EXFIRE 360	0051-CPR-0369
Control and indicating equipment with Power supply equipment	AutroSafe 4	0359-CPR-00008
Control and indicating equipment with Power supply equipment	BU-BV-420 Information Panel	0359-CPR-00008
Power Supply equipment	UTKALSCX2410E	2531-CPR-CSP11224
Control and indicating equipment with Power supply equipment and electrical automatic control and delay devices	K21042M3	0086-CPR-96748
Acessorie to the above.	Ethernet Switch FL SWITCH 2206-2FX	
Acessorie to the above.	Current Driver/Repeater KFD0-CS-2.51P	Must be connected to BN-331
Acessorie to the above.	DC-DC Converter MINI-PS-12-24DC/24DC/1	Must be connected to BZ-500
Input/output devices with Short-circuit isolators	BN-303	0333-CPR-075249
Input/output devices with Short-circuit isolators	BN-304	0333-CPR-075248
Input/output devices with Short-circuit isolators	BN-305	0470-CPD-0031 And DoP 0470-CPR-0031
Input/output devices with Short-circuit isolators	BN-307	0470-CPD-0031 And DoP 0470-CPR-0031
Input/output devices with Short-circuit isolators	BNB-331	0470-CPD-0031 And DoP 0470-CPR-0031
Input/output devices	BZ-500	0470-CPD-0030 And DoP 0470-CPD-0030
Flame detectors - Point detectors	X5200G	2831-CPR-F1178
Sounders with Visual alarm	5965-CSA	2852-CPR-0102
Sounders	IS-mA1	0786-CPD-20338 And DoP 0786-CPD-20338
Sounders	XB15	2831-CPR-F0762

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Sounders	BBR-230/P	0832-CPD-1044 And DoP 0832-CPR-1044
Visual alarm devices	PY X-S-05-SSM	0786-CPD-21219 And DoP 01CPR2013-06-07
Sounders	PA 10-SSM	0786-CPD-21224 And DoP 04CPR2013-06-07
Visual alarm devices	PY X-L-15-CPR	0786-CPR-21563
Heat detectors - Point detectors with Short-circuit isolators	BDH-500	1134-CPR-018
Smoke Point detectors using scattered light, transmitted light or ionization with Short-circuit isolators	BHH-500	1134-CPR-016
Smoke Point detectors using scattered light, transmitted light or ionization with Short-circuit isolators	BH-500/EX	1134-CPR-016
Smoke Point detectors using scattered light, transmitted light or ionization with Short-circuit isolators	SOC-E3N	0832-CPR-F1518
Manual call points with Short-circuit isolators	BF-300V2	0333-CPR-075244
Manual call points	WCPA1A-R470SF-H029-01 (CCP-W)	0832-CPR-F1715
Manual call points	WCP1A-R470SF-K013-01IS (CCP-W-IS)	0832-CPR-F1715
Aspirating smoke detectors	116-5861-018.2803	0832-CPR-F2629
Aspirating smoke detectors	116-5861-018.2801	0832-CPR-F2629
Visual alarm devices	IS-mB1-R/R	Type 2 componet must be connected to I/O unit BN-307
Remote Indicator	116-BU-47	Type 2 componet must be connected to heat detector BDH-500 or smoke detector BHH-500
Door holder	1380-15-D	Type 2 componet must be connected to I/O unit BN-305

Bilag/Annex: 2

PRØVNINGSdokUMENTATION TEST DOKUMENTATION

Akkediteret laboratorium <i>Accredited laboratory</i>	Rapport nr <i>Report no.</i>	Dato <i>Date</i>
IMQ	SS21-0065651-01	08.06.2021

Bilag/Annex: 3

TEKNISK DOKUMENTATION TECHNICAL DOCUMENTATION

Titel <i>Name</i>	Reference <i>Refence</i>	Dato <i>Date</i>
Installationshåndbog <i>Installation Manual</i>	116-P-ASAFE-INSTALL/DGB Rev. G	2011-12-06
Brugervejledning <i>Operation Manual</i>	116-P-ASAFE-OPERATE/FN Rev. B	2011-01-20
Short guide	651-AU-BS420-458	

Bilag/Annex: 4

AFVIGELSER *DEVIANCE*

No Type C dependency according to clause 7.12.3 of EN 54-2:1997/A1:2006 approved for the CIE panel AutoSafe 4. No operator access to level 3 are allowed in case the system inhibit the activation of outputs until a second alarm signal is received.