

**Autronica Fire & Security A/S**  
**Industriholmen 17-19**  
**2650 Hvidovre**  
**Denmark**

Certifikat nr.  
Certificate no.  
**253.104**

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsescertifikat for systemet  
*has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and(or) other normative documents for the system*

**FireBeta XT**                      **Automatisk rumslukningsanlæg**  
**Automatic total flooding fire extinguishing systems**

til anvendelse i automatiske rumslukningsanlæg.  
*to be used in automatic total flooding fire extinguishing systems.*

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:  
*The certificate signifies compliance with the requirements in the following standards and other normative documents:*

EN 54-13:2005                      Fire detection and fire alarm systems – Part 13:  
Compatibility assessment of system components.

DBI Guideline 003                      Fire safety systems

Ovenstående overensstemmelse er kun gældende for systemsammenvirke af komponenter der indgår i detektering og alarmfunktioner.  
*The above compliance is only valid for system compatibility of components for the detection and alarm functions.*

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.  
*The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.*

Udstedt/Issued: 2024-02-02

Udløber/Expire: 2027-02-02

Erstatter tidligere udstedt certifikat 2020-05-29

*Replace previous issued certificate 2020-05-29*



Merete Poulsen



Steen Nilsson

Bilag/Annex: 1

## OMFANG/EXTENT

EC-Certificate of Conformity no.	Autronica Fire & safety part no.	Type	Producent
2897-CPR-496748	Sigma XT/KM96761	Extinguishing panel	Kentec
1035-CPR-ES067290	MCP3A-B, MCP3A-Y, WCP3A-B, WCP3A-Y	Manual triggering and stop devices	KAC
2531-CPR-CSP11128	55000-215 -SERIES 65	IONISATION	Apollo
2531-CPR-CSP11129	55000-216 - SERIES 65	IONISATION	Apollo
2531-CPR-CSP11130	55000-217 - SERIES 65	IONISATION	Apollo
2531-CPR-CSP11132	55000-220 - SERIES 65	Intergrating IONISATION	Apollo
2531-CPR-CSP10904	55000-315 - SERIES 65	OPTICAL	Apollo
2531-CPR-CSP10905	55000-316 - SERIES 65	OPTICAL	Apollo
2531-CPR-CSP10907	55000-317 - SERIES 65	OPTICAL	Apollo
2531-CPR-CSP10879	55000-121 - SERIES 65	HEAT Class A1R	Apollo
2531-CPR-CSP10881	55000-122 - SERIES 65	HEAT Class A1R	Apollo
2531-CPR-CSP10887	55000-127 - SERIES 65	HEAT Class BR	Apollo
2531-CPR-CSP10803	55000-132 - SERIES 65	HEAT Class CR	Apollo
2531-CPR-CSP10899	55000-137 - SERIES 65	HEAT Class CS	Apollo
2531-CPR-CSP10968	ORB-OP-12001-APO	Orbis Optical	Apollo
2531-CPR-CSP11156	ORB-OH-13001-APO	Orbis Multisensor detector	Apollo
2531-CPR-CSP10954	ORB-HT-11001-APO	Orbis Class A1R Heat	Apollo
2531-CPR-CSP10959	ORB-HT-11002-APO	Orbis Class A2S Heat	Apollo
2531-CPR-CSP10960	ORB-HT-11003-APO	Orbis Class BR Heat	Apollo

2531-CPR-CSP10961	ORB-HT-11004-APO	Orbis Class BS Heat	Apollo
2531-CPR-CSP10962	ORB-HT-11005-APO	Orbis Class CR Heat	Apollo
2531-CPR-CSP10963	ORB-HT-11006-APO	Orbis Class CS Heat	Apollo
2531-CPR-CSP10966	ORB-HT-11166-APO	Orbis Class A1S Heat	Apollo
2531-CPR-CSP11157	ORB-HT-53027-APO	Orbis IS Multisensor detector	Apollo
2531-CPR-CSP11149	ORB-HT-51145-APO	Orbis IS Class A1R Heat	Apollo
2531-CPR-CSP11150	ORB-HT-51147-APO	Orbis IS Class A2S Heat	Apollo
2531-CPR-CSP11151	ORB-HT-51149-APO	Orbis IS Class BR Heat	Apollo
2531-CPR-CSP11152	ORB-HT-51151-APO	Orbis IS Class BS Heat	Apollo
2531-CPR-CSP11153	ORB-HT-51153-APO	Orbis IS Class CR Heat	Apollo
2531-CPR-CSP11154	ORB-HT-51155-APO	Orbis IS Class CS Heat	Apollo
2531-CPR-CSP11155	ORB-HT-51157-APO	Orbis IS Class A1S Heat	Apollo
2531-CPR-CSP11158	ORB-OP-52027-APO	Orbis IS Optical	Apollo

Bilag/Annex: 2

## PRØVNINGSdokUMENTATION TEST DOKUMENTATION

Akkrediteret laboratorium <i>Accredited laboratory</i>	Rapport nr <i>Report no.</i>	Dato <i>Date</i>
DELTA	DANAK-199874	2007-10-16
	Project no.: A530472	

Bilag/Annex: 3

## TEKNISK DOKUMENTATION TECHNICAL DOCUMENTATION

Titel <i>Name</i>	Dato <i>Date</i>
Betjeningsvejledning FireBeta XT+	Not dated and not versionized. Received by DBIC 2020-05-28
Betjeningsvejledning FireBeta XT Kontrolpanel for Slukningsmiddel	Rev. 001 Dato: 23-10-2007

Bilag/Annex: 4

## AFVIGELSER DEVIANCE

Intet.  
None.