



DANAK

Reg.nr. 7004



**Dansk
Brandteknisk
Institut**

CERTIFIKAT

Certificate

232.177

**Bosch Telecom GmbH,
Ludwig-Bölkow-Allee,
D-85521 Ottobrunn**

har på baggrund af typeprøvning opnået dette overensstemmelsescertifikat for
has achieved a certificate of conformity based on type approval testing for

Bosch, BS1000.
Bosch, BS1000.

til anvendelse i automatiske brandalarmanlæg.
to be used in automatic fire detection and alarm systems.

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:

The certificate signifies compliance with the requirements in the following standards and other normative documents:

- EN54-2: 04.99; Control and indicating equipment.
- EN54-4: 04.99; Power Supplies.

Afvielser fra standarder og andre normative dokumenter: Se bilag 4
Deviances from standards and other normative documents: See annex 4

Certifikatet er kun gældende for det ovenfor anførte.
The certificate is only valid for the above mentioned.

Samlet sideantal / *Total no. of pages:* 6

Udstedt / *Issued:* 1999.07.27

Gyldig til / *Valid to:* 2004.07.27

Per Rosendahl Frederiksen

Sagsbehandler
Technical Officer

Linn Classesson

Sektionsleder
Head of Section

OMFANG EXTENT



Side 3 af 6
Page 3 of 6

Bilag:1
Annex:1

Certifikat nr.: 232.177
Certificate no.: 232.177

Dato: 1999.07.27
Date: 1999.07.27

Type <i>Type</i>	Beskrivelse <i>Description</i>	For systemer: Systemdelens certifikatnr. <i>For systems: Certificate no. for system parts</i>
Kontrol- og indikerings- <i>Control and indicating equipment</i>	UEZ 2000 LSN.	232.992
Alarmtryk <i>Manual call point</i>	DM 200 LSN.	232.993
Røgdetektor <i>Smoke detector</i>	OM 200 LSN.	232.994
Termodetektor <i>Heat detector</i>	TM 200 LSN.	232.995

AFVIGELSER

DEVIANCE



Side 6 af 6
Page 6 of 6

Bilag:4
Annex:4

Certifikat nr.: 232.177
Certificate no.: 232.177

Dato: 1999.07.27
Date: 1999.07.27

Certifikatet er udstedt under forudsætning af at systemdelscertifikaterne opretsholdes. Dvs. at forbeholdene/afvigelseerne noteret på hert systemdelscertifikat bilag 4 afklares inden udgangen af 1999.

The certificate is issued under the condition that the deviances noted on each system part certificate has been corrected within 1999.