

Owner of certificate: GE Security Danmark A/S Husby Alle 15A DK-2630 Taastrup		Usefull information:				Link:
System		System part				
Name	Certificate no.	Type	Product	Certificate	Remarks	Links
FP600 System Interlogix / FF600 System Group4 Falck	232.200	DP721 / DP721S77 / DP721NLS77 / FFD4001 / FFD4001D0	Optical conventional detector with/without logo	1175 – CPD – 008		
		FFD4002D0 DP721I / DP721IS77 / DP721INLS77 / FFD4002 /	Optical detector with remote LED, with/without logo	1175 – CPD – 008		
		FFD4003D0 DP721R / DP721RS77 / DP721NLS77 / FFD4003 /	Optical detector with relay output, with/without logo	1175 – CPD – 008		
		FP604 / Interlogix G4F code - FP604S77 / G4F - FFC300604	Control og indicating equipment incl. ZI602 extension board	232.1172		
		DM700R07 / DM700R07S77 / FFD4302D1	Manual call point, with 680 ohm resistor	232.1211		
		DM700E 07/ DM700E07S77 / FFD4303D1	Manual call point	232.1212		
		DT713-5 / DT713-5NLS77 / DT713-5S77 / FFD4101D0 / FFD4110	Heat detector class A2	1175 – CPD – 005		
		DT713-5R/DT713-5RS77/FFD4102/DT713-13-5RNLS77/FFD4102D0	Heat detector w. relay, 57 dgr. C (class A2)	1175 – CPD – 005		

		DT713-7/DT713-7S77/FFD4103/DT713-7NLS77/FFD4103D0	Heat detector, 70 dg.C (class B)	1175 – CPD – 005		
--	--	---	----------------------------------	------------------	--	--