

Owner of certificate: CN System AB
Södra Långebergsgatan 34
S-421 32 V. Västra Frölunda
Sweden

Date of issue: 2010-11-02

System Name: NSAC-1 Automatic fire alarm system		Certificate no.: 232.174	
System parts			
Type	Product	Certificate	Remarks
NSAC-1	Kontrol- og indikeringsudstyr med intern strømforsyning. <i>Control and indicating equipment with power supply</i>	0845-CPD-956	
NS-SCI Kortslutningsisolator	Kortslutningsisolator <i>Short circuit isolator</i>	0845-CPD-232.958	
NS-AIN1	Adresseled <i>Input element</i>	0845-CPD-232.959	
NS-AIHS & NS-AIS	Røgdetektor ion/termo eller ion <i>Smoke detector - ionization/heat or heat</i>	0845-CPD-232.1495	
NS-AOHS & NS-AOS & NS-AOS-IS	Røgdetektor - optisk/termo eller optisk <i>Smoke detector - optical/heat or optical</i>	0845-CPD-232.1494	
NS-AH/A1S & NS-AH/CS	Termodetektor klasse A1S or CS <i>Heat detector class A1S or CS</i>	0845-CPD-232.1497	
NS-ACP NS-ACPWP	Alarmtryk IP24D / Alarmtryk IP67 <i>Manual call point IP24D / Manual call point IP67</i>	0845-CPD-232.1689	
ST-I ST-I-IS	Røgdetektor, ion. Røgdetektor, ion, for EX-anvendelse	0845-CPD-232.1493	

System Name: NSAC-1 Automatic fire alarm system		Certificate no.: 232.174	
System parts			
Type	Product	Certificate	Remarks
	<i>Smoke detector, ionozation Smoke detector, ionozation, for EX-applications.</i>		
ST-P	Røgdetektor, optisk <i>Smoke detector, optical</i>	0845-CPD-232.1492	
NHD-G1 NHD-GH1	Termodetektor, klasse A1 Termodetektor, klasse B <i>Heat detector, class A1 Heat detector, class B</i>	0845-CPD-232.1496	
MCP1A (NS-CP) WCP3A (NS-CPWP)	Alarmtryk, IP24D <i>Alarmtryk, IP67 Manual call point, IP24D Manual call point, IP67</i>	0832-CPD-0642 0832-CPD-0659	
NS-AIN2	Input adresse-element <i>Input element</i>	0845-CPD-232.1357	
NS-AIO21	I/O-element, 2 input / 1 output <i>I/O unit, 2 inputs / 1 output</i>	0845-CPD-232.1358	
CN-P	Analog addresserbar optisk røgdetektor <i>Analoge addressable photoelectrical smoke detector</i>	0832-CPD-0218	
CN-DP	Analog addresserbar 2 x optisk røgdetektor <i>Analoge addressable dual photoelectrical smoke detector</i>	0832-CPD-0219	
CN-PH	Analog addresserbar optisk røgdetektor/termodetektor klasse A1R <i>Analoge addressable photoelectrical smoke and Class A1R</i>	0832-CPD-0221	

System Name: NSAC-1 Automatic fire alarm system		Certificate no.: 232.174	
System parts			
Type	Product	Certificate	Remarks
	<i>heat detector</i>		
CN-H-A1R	Analog adresserbar termodetektor klasse A1R <i>Analogue addressable Class A1R heat detector</i>	0832-CPD-0222	
	Analog adresserbar termodetektor klasse CS <i>Analogue addressable Class CS heat detector</i>	0832-CPD-0223	
Analoge adresserbare systemdele			
CN-PS	Optisk detektor med lyd giver og isolator <i>Optical detector with sound and SCI</i>	0845-CPD-232.1710	
CN-DPH	Multisensor detector optisk/termo med termoklasse A2R & CS <i>Dual optical/heat detector – heat class A2R & CS</i>	0845-CPD-232.1685	
CN-BI	Sokkel med isolator <i>SCI base</i>	0845-CPD-232.1708	
CN-MCP2	Alarmtryk med isolator <i>Manual Call Point with SCI</i>	0845-CPD-232.1709	
CN-AIOI	I/O modul med isolator <i>Input/Output module with SCI</i>	0845-CPD-232.1707	

System Name: NSAC-1 Automatic fire alarm system		Certificate no.: 232.174	
System parts			
Type	Product	Certificate	Remarks
Konventionelle systemdele:			
EVC-P	Optisk sensor <i>Optical sensor</i>	0832-CPD-220	
EVC-PY	Optisk røgdetektor <i>Optical smoke detector</i>	0786-CPD-20436	
EVC-DP	2 x Optisk detektor <i>Dual optical detector</i>	0832-CPD-542	
EVC-IR	2 x Flamme detector <i>Dual Flame Detector</i>	0832-CPD-1081	
EVC-H	Termodetektor: Klasse A2S Klasse CS <i>Heat detector</i> <i>Class A2S</i> <i>Class CS</i>	0832-CPD-224 0832-CPD-225	