

CERTIFICATE

Honeywell Life Safety AS
P.O.Box 3514
3007 Drammen
Norway

Certifikat nr.
Certificate no.
232.237

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsescertifikat for systemet
has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and (or) other normative documents for the system

BSX 100

Automatisk Branddetekterings- og Alarm-system
Automatic Fire Detection and Alarm System

til anvendelse i automatiske brandalarmanlæg.
to be used in automatic fire detection and alarm systems.

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:
The certificate signifies compliance with the requirements in the following standards and other normative documents:

EN 54-13: 2005 Fire detection and fire alarm systems – Part 13:
Compatibility assessment of system components.

DBI Guideline 003 Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.
The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.

Udstedt / Issued: 2020-02-11

Udløber/expire: 2023-02-11

Erstatter tidligere udstedt certifikat 2019-10-10
Replace previous issued certificate 2019-10-10



Allan Laursen



Merete Poulsen

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Kontrol- og indikeringsudstyr <i>Control and Indicating Equipment</i>	BSX 100	0786-CPD-20800
Analogue addressable CI detector ass A1R photo/thermal smoke	ECO1002	0832-CPD-0065
Conventional optical smoke detector	ECO1003	0832-CPD-0064
Conventional Class BS fixed temperature heat detector	ECO1004T	0845-CPD-0068
Conventional Class A1R rate of rise heat detector	ECO1005	0845-CPD-0066
Conventional Class A2S fixed temperature heat detector	ECO1005T	0845-CPD-0067
Conventional wall mounting Type A 4 tone sounder (red)	EMA1224B4R	0845-CPD-0301
KAC Manual call point	MCP1A-R470FG-01	0832-CPD-0642
KAC Manual call point	MCP1A-R470SG-01	

Bilag/Annex: 2

PRØVNINGSdokUMENTATION
TEST DOKUMENTATION

Akkediteret laboratorium <i>Accredited laboratory</i>	Rapport nr <i>Report no.</i>	Dato <i>Date</i>
BRE / LPCB	TE213153	2005-07-05

Bilag/Annex: 3

TEKNISK DOKUMENTATION
TECHNICAL DOCUMENTATION

Titel Name	Reference Refence	Dato Date
Der henvises til dokumentation for de enkelte systemdele.		
<i>Please reference to the documentation for each system part.</i>		

Bilag/Annex: 4

AFVIGELSER **DEVIANCE**

DBI Certification har accepteret, at systemtest er udført efter LPS1054: Issue 2.1: 2003, der er det engelske modstykke til den danske Forskrift 232: Prøvningsdelen.

DBI Certification has accepted that the compatibility test is performed according to LPS1054: Issue 2.1: 2003, that is an English equivalent to the Danish Forskrift 232: Prøvningsdelen.