

# CERTIFICATE

**Securiton AG**  
**Alpenstrasse 20**  
**Postfach 666**  
**CH-3052 Zollikofen Switzerland**

Certifikat nr.  
Certificate no.  
**232.278**

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsescertifikat for systemet  
*has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and(or) other normative documents for the system*

**SecuriFire FCP 500**      **Automatisk Branddetekterings- og Alarm-system**  
**Automatic Fire Detection and Alarm System**

til anvendelse i automatiske brandalarmanlæg.  
*to be used in automatic fire detection and alarm systems.*


Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:  
*The certificate signifies compliance with the requirements in the following standards and other normative documents:*

EN 54-13: 2005      Fire detection and fire alarm systems – Part 13:  
Compatibility assessment of system components.

DBI Guideline 003      Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.  
*The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.*

Udstedt / *Issued*: 2019-10-10  
Udløber/*expire*: 2021-06-14  
Erstatter tidligere udstedt certifikat 2019-08-14  
*Replace previous issued certificate 2019-08-14*



Allan Laursen



Merete Poulsen

**Bilag/Annex: 1**

**OMFANG/EXTENT**

<b>Type Type</b>	<b>Produkt Product</b>	<b>Certifikat Certificate</b>
Control and indicating equipment with power supply equipment	SecuriFire FCP 500	0786-CPR-21185
In -/Output Devices with short-circuit isolator.	BX-OI3	0786-CPD-21011 and DOP CPR-20-13-005
In -/Output Devices with short-circuit isolator.	BX-O2I4	0786-CPD-21066 and DOP CPR-20-13-012
In -/Output Devices with short-circuit isolator.	BX-IOM	0786-CPD-21010 and DOP CPR-20-13-006
Input Devices with short-circuit isolator.	BX-REL4	0786-CPD-21012 and DOP CPR-20-13-008
In -/Output Devices with short-circuit isolator.	BX-IM4	0786-CPD-21009 and DOP CPR-20-13-007
In -/Output Devices with short-circuit isolator.	BX-AIM, Detachable and Software controlled I/O with integrate SCI.	0786-CPR-20601
Smoke and Heat point detector With short-circuit isolator.	CCD 573X, adressable	0786-CPR-21215
Smoke and Heat point detector With short-circuit isolator.	MCD 573X, adressable	0786-CPR-21020
Smoke and Heat point detector With integrate lighth	MMD 130 Ex-i	0786-CPR-21104
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-S, Software controlled I/O with integrate SCI	0786-CPR-21278
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-SP, Software controlled I/O with integrate SCI	0786-CPR-21278
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-SP EE, Software controlled I/O with integrate SCI	0786-CPR-21278
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-SP AE, Software controlled I/O with integrate SCI	0786-CPR-21278
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-SCT, Software controlled I/O with integrate SCI	0786-CPR-21278

Bilag/Annex: 1

## OMFANG/EXTENT

Type <i>Type</i>	Produkt <i>Product</i>	Certifikat <i>Certificate</i>
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-SPCT, Software controlled I/O with integrate SCI	0786-CPR-21278
Manual call point With integrate short-circuit isolator	MCP 545X-1N	0786-CPD- 20998 and DOP CPR-20-13-300
Manual call point With integrate short-circuit isolator	MCP 545X-1AN	0786-CPD- 20998 and DOP CPR-20-13-300
Manual call point With integrate short-circuit isolator	MCP 545X-N	0786-CPD- 20998 and DOP CPR-20-13-300
Manual call point With integrate short-circuit isolator	MCP 545X-2N	0786-CPD- 20998 and DOP CPR-20-13-300
Manual call point With integrate short-circuit isolator	MCP 545X-4N, Outdoor use.	0786-CPD- 20998 and DOP CPR-20-13-300
Sounder With integrate short-circuit isolator	BX-SOL, With Software controlled SCI	0786-CPR-20986
Sounder With integrate short-circuit isolator	BX-SOL-CT, With Software controlled SCI	0786-CPR-20986
Sounder With integrate short-circuit isolator	BX-SBL502	0786-CPD-21065 and DOP CPR-20-13-101
Short-circuit isolator	BX-FOL, optical Alarm Device	0786-CPD-20987 and DOP CPR-20-14-102
Short-circuit isolator	BX-FOL-RR, optical Alarm Device	0786-CPD-20987 and DOP CPR-20-14-102
Short-circuit isolator	BX-FOL-WR, optical Alarm Device	0786-CPD-20987 and DOP CPR-20-14-102
Short-circuit isolator	BX-FOL-RO, optical Alarm Device	0786-CPD-20987 and DOP CPR-20-14-102
Short-circuit isolator	BX-FOL-WO, optical Alarm Device	0786-CPD-20987 and DOP CPR-20-14-102
Aspirating smoke detectors with short-circuit isolator.	ASD 535, With detachable SCI.	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator.	ASD 535-1, With detachable SCI.	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator.	ASD 535-1 SE, With detachable SCI	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator.	ASD 535-2, With detachable SCI.	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator.	ASD 535-2 SE, With detachable SCI.	0786-CPR-20600

Bilag/Annex: 1

**OMFANG/EXTENT**

Type <i>Type</i>	Produkt <i>Product</i>	Certifikat <i>Certificate</i>
Aspirating smoke detectors with short-circuit isolator.	ASD 535-3, With detachable SCI.	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator.	ASD 535-3 SE, With detachable SCI.	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator.	ASD 535-4, With detachable SCI.	0786-CPR-20600
Aspirating smoke detectors with short-circuit isolator.	ASD 535-4 SE, With detachable SCI.	0786-CPR-20600
Smoke detector with short-circuit isolator.	ILIA ERHS0712, Without reflector, with integrate SCI	0786-CPR-209925
Smoke detector with short-circuit isolator.	ILIA ERRHS0712, with integrate SCI	0786-CPR-209925
Line-type Heat Detector ONLY EMC tested	LIST	Only tested for EMC EN 50130-4:2011 test report no. 120502-AU01+UCE01
Line-type Heat Detector ONLY EMC tested	d-List	Only tested for EMC EN 50130-4:2011 test report no. BMA 05129
Line-type Heat Detector ONLY EMC tested	ADW 535	Only tested for EMC EN 50130-4:2011 test report no. 122547-AU01-UC EE01- PB01 and 142341- AU01+UCE01-PB01

Bilag/Annex: 2

**PRØVNINGSdokUMENTATION**  
**TEST DOKUMENTATION**

<b>Akkediteret laboratorium <i>Accredited laboratory</i></b>	<b>Rapport nr <i>Report no.</i></b>	<b>Dato <i>Date</i></b>
VdS	BMA 14090	03.09.2014

Bilag/Annex: 3

**TEKNISK DOKUMENTATION**  
**TECHNICAL DOCUMENTATION**

<b>Titel Name</b>	<b>Reference Refence</b>	<b>Dato Date</b>
Installation manual	T 811 065 en c	2018-05-02
Display and operating unit With 5.7" display, Danish	T811047 da	2018-05-02
Betjeningsvejledning	T 811 091 da f	2018-05-02

Bilag/Annex: 4

## **AFVIGELSER** *DEVIANCE*

- The system can not be used as networked systems.
- The system can not be used in a hierarchical systems.