

CERTIFICATE

Securiton AG
Alpenstrasse 20
Postfach 666
CH-3052 Zollikofen Switzerland

Certifikat nr.
Certificate no.
232.280

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsescertifikat for systemet
has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and(or) other normative documents for the system

SecuriFire FCP 2000 **Automatisk Branddetekterings- og Alarm-system**
Automatic Fire Detection and Alarm System

til anvendelse i automatiske brandalarmanlæg.
to be used in automatic fire detection and alarm systems.

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:
The certificate signifies compliance with the requirements in the following standards and other normative documents:

EN 54-13: 2005 Fire detection and fire alarm systems – Part 13:
Compatibility assessment of system components.


DBI Guideline 003 Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.
The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.

Udstedt / Issued: 2019-10-10

Udløber/expire: 2021-08-29

Erstatter tidligere udstedt certifikat 2019-08-14
Replace previous issued certificate 2019-08-14



Allan Laursen



Merete Poulsen

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Control and indicating equipment with power supply equipment	SecuriFire FCP 2000	0786-CPR-20717
In -/Output Devices with short-circuit isolator.	BX-OI3	0786-CPD-21011 and DOP CPR-20-13-005
In -/Output Devices with short-circuit isolator.	BX-O2I4	0786-CPD-21066 and DOP CPR-20-13-012
In -/Output Devices with short-circuit isolator.	BX-IOM	0786-CPD-21010 and DOP CPR-20-13-006
Input Devices with short-circuit isolator.	BX-REL4	0786-CPD-21012 and DOP CPR-20-13-008
In -/Output Devices with short-circuit isolator.	BX-IM4	0786-CPD-21009 and DOP CPR-20-13-007
In -/Output Devices with short-circuit isolator.	BX-AIM, Detachable and Software controlled I/O with integrate SCI.	0786-CPR-20601 and DOP CPR-20-13-009
Smoke and Heat point detector With short-circuit isolator.	CCD 573X, adressable	0786-CPR-21215 and CPR-10-13-300
Smoke and Heat point detector With short-circuit isolator.	MCD 573X, adressable	0786-CPR-21020 and DOP CPR-10-13-302
Smoke and Heat point detector With integrate lighth	MMD 130 Ex-i	0786-CPR-21104
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-S, Software controlled I/O with integrate SCI	0786-CPR-21278 and DOP CPR-10-13-307
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-SP, Software controlled I/O with integrate SCI	0786-CPR-21278 and DOP CPR-10-13-307
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-SP EE, Software controlled I/O with integrate SCI	0786-CPR-21278 and DOP CPR-10-13-307
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-SP AE, Software controlled I/O with integrate SCI	0786-CPR-21278 and DOP CPR-10-13-307
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-SCT, Software controlled I/O with integrate SCI	0786-CPR-21278 and DOP CPR-10-13-307

Bilag/Annex: 1

OMFANG/EXTENT

Type <i>Type</i>	Produkt <i>Product</i>	Certifikat <i>Certificate</i>
Smoke and Heat point detector With integrate sounder and short-circuit isolator.	MCD 573X-SPCT, Software controlled I/O with integrate SCI	0786-CPR-21278 and DOP CPR-10-13-307
Manual call point With integrate short-circuit isolator	MCP 545X-1N	0786-CPD- 20998 and DOP CPR-20-13-300
Manual call point With integrate short-circuit isolator	MCP 545X-1AN	0786-CPD- 20998 and DOP CPR-20-13-300
Manual call point With integrate short-circuit isolator	MCP 545X-N	0786-CPD- 20998 and DOP CPR-20-13-300
Manual call point With integrate short-circuit isolator	MCP 545X-2N	0786-CPD- 20998 and DOP CPR-20-13-300
Manual call point With integrate short-circuit isolator	MCP 545X-4N, Outdoor use.	0786-CPD- 20998 and DOP CPR-20-13-300
Sounder With integrate short-circuit isolator	BX-SOL, With Software controlled SCI	0786-CPR-20986 and DOP CPR-20-13-100
Sounder With integrate short-circuit isolator	BX-SOL-CT, With Software controlled SCI	0786-CPR-20986 and DOP CPR-20-13-100
Sounder With integrate short-circuit isolator	BX-SBL502	0786-CPD-21065 and DOP CPR-20-13-101
Short-circuit isolator	BX-FOL, optical Alarm Device	0786-CPD-20987 and DOP CPR-20-14-102
Short-circuit isolator	BX-FOL-RR, optical Alarm Device	0786-CPD-20987 and DOP CPR-20-14-102
Short-circuit isolator	BX-FOL-WR, optical Alarm Device	0786-CPD-20987 and DOP CPR-20-14-102
Short-circuit isolator	BX-FOL-RO, optical Alarm Device	0786-CPD-20987 and DOP CPR-20-14-102
Short-circuit isolator	BX-FOL-WO, optical Alarm Device	0786-CPD-20987 and DOP CPR-20-14-102
Aspirating smoke detectors with short-circuit isolator.	ASD 535, With detachable SCI. Only via I/O BX-O13	0786-CPR-20600 and DOP CPR-10-13-101
Aspirating smoke detectors with short-circuit isolator.	ASD 535-1, With detachable SCI. Only via I/O BX-O13	0786-CPR-20600 and DOP CPR-10-13-101
Aspirating smoke detectors with short-circuit isolator.	ASD 535-1 SE, With detachable SCI. Only via I/O BX-O13	0786-CPR-20600 and DOP CPR-10-13-101
Aspirating smoke detectors with short-circuit isolator.	ASD 535-2, With detachable SCI. Only via I/O BX-O13	0786-CPR-20600 and DOP CPR-10-13-101
Aspirating smoke detectors with short-circuit isolator.	ASD 535-2 SE, With detachable SCI. Only via I/O BX-O13	0786-CPR-20600 and DOP CPR-10-13-101

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Aspirating smoke detectors with short-circuit isolator.	ASD 535-3, With detachable SCI. Only via I/O BX-O13	0786-CPR-20600 and DOP CPR-10-13-101
Aspirating smoke detectors with short-circuit isolator.	ASD 535-3 SE, With detachable SCI. Only via I/O BX-O13	0786-CPR-20600 and DOP CPR-10-13-101
Aspirating smoke detectors with short-circuit isolator.	ASD 535-4, With detachable SCI. Only via I/O BX-O13	0786-CPR-20600 and DOP CPR-10-13-101
Aspirating smoke detectors with short-circuit isolator.	ASD 535-4 SE, With detachable SCI. Only via I/O BX-O13	0786-CPR-20600 and DOP CPR-10-13-101
Smoke detector with short-circuit isolator.	ILIA ERHS0712, Without reflector, with integrate SCI Only via I/O BX-O13	0786-CPR-20925
Smoke detector with short-circuit isolator.	ILIA ERRHS0712, with integrate SCI Only via I/O BX-O13	0786-CPR-20925
Line-type Heat Detector ONLY EMC tested	LIST Only via I/O BX-O13	Only tested for EMC EN 50130-4:2011 test report no. 120502- AU01+UCE01
Line-type Heat Detector ONLY EMC tested	d-List Only via I/O BX-O13	Only tested for EMC EN 50130-4:2011 test report no. BMA 05129
Line-type Heat Detector ONLY EMC tested	ADW 535 Only via I/O BX-O13	Only tested for EMC EN 50130-4:2011 test reportr no. 122547-AU01- UCEE01-PB01 and 142341- AU01+UCE01-PB01

Bilag/Annex: 2

PRØVNINGSDOKUMENTATION
TEST DOKUMENTATION

Akkediteret laboratorium <i>Accredited laboratory</i>	Rapport nr <i>Report no.</i>	Dato <i>Date</i>
VdS	BMA 14088	03.09.2014

Bilag/Annex: 3

TEKNISK DOKUMENTATION
TECHNICAL DOCUMENTATION

Titel Name	Reference Refence	Dato Date
Installation manual	T 811 086 en f	2018-08-14
Display and operating unit With 5.7" display, Danish	T811047 da	2017-04-17
Betjeningsvejledning	T 811 091 da f	2017-05-08

Bilag/Annex: 4

AFVIGELSER *DEVIANCE*

Intet.
None.