

CERTIFICATE

RE-L SIKRING IVS
Tinningvej 4
8382 Hinnerup

Certifikat nr.
Certificate no.
232.285

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsecertifikat for systemet
has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and (or) other normative documents for the system

FCS-Detectomat

Automatisk Branddetekterings- og Alarm-system
Automatic Fire Detection and Alarm System

til anvendelse i automatiske brandalarmanlæg.
to be used in automatic fire detection and alarm systems.

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:
The certificate signifies compliance with the requirements in the following standards and other normative documents:

EN 54-13: 2005 Fire detection and fire alarm systems – Part 13:
Compatibility assessment of system components.

DBI Guideline 003 Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.
The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.

Udstedt / *Issued*: 2020-01-16
Udløber/*expire*: 2022-12-19

Erstatter tidligere udstedt certifikat 2019-12-19
Replace previous issued certificate 2019-12-19



Merete Poulsen



Allan Laursen

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Control and indicating equipment	Dc3500 SL, FCP 3500 SL	786-CPR-21428
Control and indicating equipment	Dc3500 ML, FCP 3500 ML	786-CPR-21428
Accessories to the above	Loop module for fire control panel dc3500, protected, CP 3500 LOM P	
Accessories to the above	Fire Brigade module for dc3500, protected, CP FBM P	
Accessories to the above	Basic module for dc3500, protected, CP 3500 BBM P	
Accessories to the above	Printer module for dc3500, CP 3500 PRM	
Accessories to the above	Adapter for detect 3500, ADP 4000 for CON-X	
Input/output device	PL 3321 ECM	0786-CPR-21491
Power supply	Primary pulsed power supply, BF362-1	0786-CPR-20891
Power supply	Primary pulsed power supply, BF362-3	0786-CPR-21419
Power supply	Primary pulsed power supply, BF362-5	0786-CPR-20892
Smoke detector with isolator	PL 3300 O	0786-CPR-20679
Thermal detector with isolator	PL 3300 T	0789-CPD-20044 + DOP dated 20/05/2019
Multi sensor detector (heat and smoke with isolator)	PL 3300 OTi Fusion	0786-CPD-20580 + DOP dated 23/02/2018
Multi sensor detector (heat and smoke with isolator)	PL 3300 OTi	0789-CPD-20578 + DOP dated 23/02/2018
Optical smoke detector using scattered light with isolator	PL 3305 O	0786-CPD-20041 + DOP dated 23/02/2018

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Detector base to the above detectors	Detector base loop SDBB 3000	
Optical smoke detector using scattered light with isolator	PL 3301 O	0786-CPR-20037
Detector base to the above detectors	Detector base loop SDB 3000	
Addressable manual call point with isolator	PL 3300 PBDH	0786-CPD-20382 + DOP dated 23/02/2018
Addressable manual call point with isolator	PL 3300 MCP	0333-CPR-075280
Addressable manual call point	PL 3300 PBD-Alu-R B	0786-CPD-20382 + DOP dated 23/02/2018
Addressable input/output module with isolator	IOM 3311	0786-CPD-20459 + DOP dated 23/02/2018
Addressable input/output module with isolator	IOM 3322	0786-CPD-20459 + DOP dated 23/02/2018
Addressable input/output module with isolator	OMS 3301	0786-CPD-20460 + DOP dated 23/02/2018
Addressable input/output module with isolator	AMD 3311	0786-CPD-20530+ DOP dated 23/02/2018
Addressable input/output module with isolator	OMS 3301 mini	0786-CPD-20530+ DOP dated 23/02/2018
Addressable input/output module with isolator	PL 3321 ECM	0786-CPR-21491
Addressable input/output module with isolator	TCM 3300	0786-CPR-20373
Addressable input/output module	PCA 300s	0333-CPR-075548
Sounder with isolator	PL 3300 S 0 SE	0786-CPR-21279
Sounder with isolator	PL 3300 S 1 SE	0786-CPR-21279

Bilag/Annex: 1

OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Sounder	PL 3300w CONUS S	1438-CPR-0637
Sounder	PL 3300r CONUS S	1438-CPR-0637
Input/output device	Detector parallel indicator PA	0786-CPR-20804
Visual/acoustical alarm device	CT 3000 SF 0 SE	0786-CPR-21525
Visual/acoustical alarm device	CT 3000 SF 1 SE	0786-CPR-21525
Sounder	CT 3000 S 0 SE	0786-CPR-21268
Sounder	CT 3000 S 1 SE	0786-CPR-21268
Sounder	CS 200 R	0832-CPD-1654 + DOP dated 26/06/2013
Sounder	CS 200 W	0832-CPD-1654 + DOP dated 26/06/2013
Input/output device	Detector parallel indicator PA	0786-CPR-20804
Visual alarm device	ROLP LX WALL BASE	0333-CPR-75444
Line-type smoke detector	Fireray 3000	0786-CPR-21162
Line-type smoke detector	Fireray 5000	0832-CPR-F0390
Line-type smoke detector	Fireray One	0832-CPR-F2237
Aspirating smoke detector	Stratos Micra 100	0832-CPD-0982 + DOP dated 15/03/2013
Aspirating smoke detector	Stratos Micra 25	0832-CPD-0981 + DOP dated 15/03/2013

Bilag/Annex: 2

PRØVNINGSdokUMENTATION
TEST DOKUMENTATION

Akkediteret laboratorium <i>Accredited laboratory</i>	Rapport nr <i>Report no.</i>	Dato <i>Date</i>
VdS	Test Report No. 140869- AU01+BZA02-PB01	03.02.2016

Titel Name	Reference Refence
Installation manual	Fire Control Panel dc3500 V3.4.x Installation manual 6.5.1. Password entry
Betjeningsvejledning	Brandcentral dc3500 V3.4.x Brugermanual
Kvikguide	Kvikguide til FCP dc3500 (V3.1.2)

Bilag/Annex: 4

AFVIGELSER *DEVIANCE*

Not applicable for networked systems.