

# CERTIFICATE

**Pro-Sec A/S**  
**Egegårdsvej 11**  
**4621 Gadstrup**

Certifikat nr.  
Certificate no.  
**232.289**

har på baggrund af vurderede systemegenskaber baseret på systemprøvningsrapport(er) for overensstemmelse mellem systembeskrivelse og gældende specifikationer i systemstandarder og/eller andre normative dokumenter opnået dette overensstemmelsecertifikat for systemet  
*has achieved this certificate of conformity based on evaluation of system approval test report(s) for conformity between system standards and(or) other normative documents for the system*

**Previdia Fire**

**Automatisk Branddetekterings- og Alarm-system**  
**Automatic Fire Detection and Alarm System**

til anvendelse i automatiske brandalarmanlæg.  
*to be used in automatic fire detection and alarm systems.*

Certifikatet tilkendegiver overensstemmelse med kravene i følgende standarder og andre normative dokumenter:  
*The certificate signifies compliance with the requirements in the following standards and other normative documents:*

EN 54-13:2005      Fire detection and fire alarm systems – Part 13:  
Compatibility assessment of system components.

DBI Guideline 003      Fire safety systems

Certifikatet er kun gældende så længe systemet er i overensstemmelse med ovennævnte samt kravene i certificeringsordningen.  
*The certificate is only valid as long as the system is in conformity with the above mentioned and the requirements of the certification system.*

Udstedt / Issued: 2021-03-25

Udløber/expire: 2024-03-25

Erstatter tidligere udstedt certifikat  
*Replace previous issued certificate*



Allan Laursen



Merete Poulsen

**Bilag/Annex: 1**

**OMFANG/EXTENT**

Type Type	Produkt Product	Certifikat Certificate
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C200LZEG; red enclosure	0051-CPR-1498
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C200LZG Without Electrical Automatic Control and Delay Device	0051-CPR-1498
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C200LZR Without Electrical Automatic Control and Delay Device; red enclosure	0051-CPR-1498
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C200LG Without Electrical Automatic Control and Delay Device and without Zone LED Board (PCB Code IN238-R0)	0051-CPR-1498
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C200LR Without Electrical Automatic Control and Delay Device and without Zone LED Board (PCB Code IN238-R0); red enclosure	0051-CPR-1498
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C100LG with 1 loop line (240 detectors and/or manual call points managed) and without Electrical Automatic Control and Delay Device and Zone LED Board(PCB code IN238-R0)	0051-CPR-1498
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C100LR with 1 loop line (240 detectors and/or manual call points managed) and without Electrical Automatic Control and Delay Device and Zone LED Board(PCB code IN238-R0); red enclosure	0051-CPR-1498
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C050LG with 1 loop line (64 detectors and/or manual call points managed) and without Electrical Automatic Control and Delay Device and Zone LED Board(PCB code IN238-R0)	0051-CPR-1498
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C050LR with 1 loop line (64 detectors and/or manual call points managed) and without Electrical Automatic Control and Delay Device and Zone LED Board(PCB code IN238-R0); red enclosure	0051-CPR-1498

**Bilag/Annex: 1**

## OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C200SZER; red enclosure	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C200SZG Without Electrical Automatic Control and Delay Device	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C200SZR Without Electrical Automatic Control and Delay Device; red enclosure	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C200SG Without Electrical Automatic Control and Delay Device and Zone LED Board(PCB code IN238-R0)	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C200SR Without Electrical Automatic Control and Delay Device and Zone LED Board(PCB code IN238-R0) ; red enclosure	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C100SZEG With 1 loop line (240 detectors and/or manual call points managed)	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C100SZER With 1 loop line (240 detectors and/or manual call points managed); red enclosure	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C100SZG With 1 loop line (240 detectors and/or manual call points managed) and without Electrical Automatic Control and Delay Device	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C100SZR With 1 loop line (240 detectors and/or manual call points managed) and without Electrical Automatic Control and Delay Device; red enclosure	0051-CPR-1499

Bilag/Annex: 1

## OMFANG/EXTENT

Type Type	Produkt Product	Certifikat Certificate
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C100SG With 1 loop line (240 detectors and/or manual call points managed) and without Electrical Automatic Control and Delay Device and without Zone LED Board (PCB code IN238-R0)	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C100SR With 1 loop line (240 detectors and/or manual call points managed) and without Electrical Automatic Control and Delay Device and without Zone LED Board (PCB code IN238-R0); red enclosure	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C050SZEG With 1 loop line (64 detectors and/or manual call points managed)	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C050SZER With 1 loop line (64 detectors and/or manual call points managed); red enclosure	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C050SZG With 1 loop line (64 detectors and/or manual call points managed) and without electrical Automatic Control and Delay Device	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C050SZR With 1 loop line (64 detectors and/or manual call points managed) and without electrical Automatic Control and Delay Device; red enclosure	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C050SG With 1 loop line (64 detectors and/or manual call points managed) and without electrical Automatic Control and Delay Device and without Zone LED Board (PCB code IN238-R0)	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment (optional) and Electrical automatic control and delay Device (optional)	PREVIDIA-C050SR With 1 loop line (64 detectors and/or manual call points managed) and without electrical Automatic Control and Delay Device and without Zone LED Board (PCB code IN238-R0) ; red enclosure	0051-CPR-1499
Control and indicating equipment with integrated power supply alarm transmission, fault warning routing equipment and Electrical automatic control and delay Device	PREVIDIA 216 and PREVIDIA 216R	0051-CPR-1863
Power supply equipment	SPS24160S	0051-CPR-0433

**Bilag/Annex: 1**

**OMFANG/EXTENT**

<b>Type Type</b>	<b>Produkt Product</b>	<b>Certifikat Certificate</b>
Power supply equipment	SPS24060S	0051-CPR-0434
Heat detector and Smoke detectors - Point detectors using scattered light, transmitted light or ionization with Short Circuit Isolator	ED300 Intelligent Analogue Addressable Smoke(optical) and Class P Heat detector with integrated SCI	0051-CPR-1876
Smoke detectors - Point detectors using scattered light, transmitted light or ionization with Short Circuit Isolator	ED100 Intelligent Analogue Addressable optical Smoke detectors with integrated SCI	0051-CPR-1878
Heat detectors with Short Circuit Isolator	ED200 Intelligent Analogue Addressable Class P Heat detector with integrated SCI	0051-CPR-1877
Input/output devices with Short Circuit Isolator	EM312SR Intelligent Analogue Addressable mini Input/output module with integrated SCI	0051-CPR-1872
Input/output devices with Short Circuit Isolator	EU311 Intelligent Analogue Addressable micro input/output module with integrated SCI	0051-CPR-1871
Input/output devices with Short Circuit Isolator	EM344R Intelligent Analogue Addressable 4 input/ 4 relay output module with integrated SCI	0051-CPR-1870
Input/output devices with Short Circuit Isolator	EM344S Intelligent Analogue Addressable 4 input/ 4 relay output module with integrated SCI	0051-CPR-1869
Input/output devices with Short Circuit Isolator	EM340 Intelligent Analogue Addressable 4 input module with integrated SCI	0051-CPR-1868
Input/output devices with Short Circuit Isolator	EM304S Intelligent Analogue Addressable 4 supervised input module with integrated SCI	0051-CPR-1866
Input/output devices with Short Circuit Isolator	EM304R Intelligent Analogue Addressable 4 relay output module with integrated SCI	0051-CPR-1867
Manual call points with Short Circuit Isolator	EC0020 Adressable Type A indoor re-settable manual call point with integrated SCI	051-CPR-1865
Sounders with Short Circuit Isolator	ES203WE Adressable Wall sounder with voice function with integrated SCI	0051-CPR-1317
Sounders with Short Circuit Isolator	ES203RE Adressable Wall sounder with voice function and integrated SCI	0051-CPR-1317
Sounders with Short Circuit Isolator	ESB1010 Adressable Base sounder with integrated SCI	0051-CPR-1317
Sounders with Short Circuit Isolator	ESB1030 Adressable Base Ceiling sounder with voice function and integrated SCI	0051-CPR-1317
Sounders with Short Circuit Isolator	ES1010 Adressable Ceiling sounder with integrated SCI	0051-CPR-1317
Sounders with Short Circuit Isolator	ES1030 Adressable Ceiling sounder with voice function and integrated SCI	0051-CPR-1317
Sounders with Short Circuit Isolator	ES2010RE Adressable Wall sounder with integrated SCI	0051-CPR-1317

**Bilag/Annex: 1**

**OMFANG/EXTENT**

<b>Type Type</b>	<b>Produkt Product</b>	<b>Certifikat Certificate</b>
Sounders with Short Crcuit Isolator	ES2010WE Adressable Wall sounder with integrated SCI	0051-CPR-1317
Sounders with Short Crcuit Isolator	CWS100+ALWS-MOD Altair Adressable Type A/B (Indoor/Outdoor) Wall sounder with integrated SCI and input/output device.	2531-CPR-F0992
Sounders	IS203WE Conventional Wall sounder with voice function	0051-CPR-1319
Sounders	IS2030RE Conventional Wall sounder with voice function	0051-CPR-1319
Sounders	ISB1010 Conventional base sounder	0051-CPR-1319
Sounders	ISB1030 Conventional base sounder with voice function	0051-CPR-1319
Sounders	IS1010 Conventional ceiling sounder	0051-CPR-1319
Sounders	IS1030 Conventional ceiling sounder with voice function	0051-CPR-1319
Sounders	IS2010RE Conventional wall sounder	0051-CPR-1319
Sounders	IS2010WE Conventional wall sounder with voice function	0051-CPR-1319
Sounders	Roshni LP (ROLP/SV) Conventional Type A/B sounder	0832-CPD-1651 and DoP0059
Sounders with Short Crcuit Isolator and visual alarm	ES2050WE Addressable wall sounder beacon with voice function and short-circuit isolators	0051-CPR-1316
Sounders with Short Crcuit Isolator and visual alarm	ES2050RE Addressable wall sounder beacon with voice function and short-circuit isolators	0051-CPR-1316
Sounders with Short Crcuit Isolator and visual alarm	ESB1020 Addressable base sounder beacon with short-circuit isolators	0051-CPR-1316
Sounders with Short Crcuit Isolator and visual alarm	ESB1050 Addressable base sounder beacon with voice function and short-circuit isolators	0051-CPR-1316
Sounders with Short Crcuit Isolator and visual alarm	ES1020 Addressable ceiling sounder beacon with short-circuit isolators	0051-CPR-1316
Sounders with Short Crcuit Isolator and visual alarm	ES1050 Addressable ceiling sounder beacon with voice function and short-circuit isolators	0051-CPR-1316
Sounders with Short Crcuit Isolator and visual alarm	ES2020RE Addressable wall sounder beacon with short-circuit isolators	0051-CPR-1316
Sounders with Short Crcuit Isolator and visual alarm	ES2020WE Addressable wall sounder beacon with short-circuit isolators	0051-CPR-1316

Sounders with Short Circuit Isolator	CWS100-AV+ALWS-MOD Altair Addressable Type A/B (Indoor/Outdoor) Wall sounder and Visual Alarm with integrated SCI and input/output device.	2531-CPR-F0993
Sounders with visual alarm	IS2050WE Conventional wall sounder and visual with voice function	0051-CPR-1318
Sounders with visual alarm	IS2050RE Conventional wall sounder and visual with voice function	0051-CPR-1318
Sounders with visual alarm	ISB1020 Conventional base sounder and visual alarm	0051-CPR-1318
Sounders with visual alarm	ISB1050 Conventional base sounder and visual alarm with voice function	0051-CPR-1318
Sounders with visual alarm	IS1020 Conventional ceiling sounder and visual alarm	0051-CPR-1318
Sounders with visual alarm	IS1050 Conventional ceiling sounder and visual alarm with voice function	0051-CPR-1318
Sounders with visual alarm	IS2020WE Conventional wall sounder and visual alarm	0051-CPR-1318
Sounders with visual alarm	IS2020RE Conventional wall sounder and visual alarm	0051-CPR-1318
Input/output devices with Short Circuit isolator using Radio link	VW2W100 Wire to Wireless Translator Module	2831-CPR-F1270
Input/output devices with Short Circuit	EM411R Input Device with integrated SCI	2831-CPR-2027
Input/output devices with Short Circuit	EM110 Input Device with integrated SCI	2831-CPR-2028
Input/output devices with Short Circuit	EM500 Input Device with integrated SCI	2831-CPR-2029
Manual call points using radio link	SGCP100 Wireless Type A Resettable Indoor Manual call point	2831-CPR-F4042
Manual call points	CWC99 Conventional Type A Outdoor Manual Call Point	2831-CPR-F2708
Input/output devices using Radio link	SGMCB200 Wireless Battery Powered Output Module	2831-CPR-F0690
Input/output devices using Radio link	SGMI200 Wireless Battery Powered Input Module	2831-CPR-F0691
Sounders using radio link	SGRBS100-AV/L Sounder using radio link	0051-CPR-1815
Sounders using radio link	SGRBS100/L Sounder using radio link	0051-CPR-1815
Sounders using radio link	SGWS-MOD + CWS100 Sounder using radio link	0051-CPR-0464
Smoke detectors - Point detectors using scattered light, transmitted light or ionization using radio links	L-OP-SG Wireless Libra Addressable Optical smoke detector using radio link	2831-CPR-F1303
Heat detectors - Point detectors using radio links	L-HT-SG Wireless Libra Addressable Class P heat detector using radio link	2831-CPR-F1302

Heat detector and Smoke detectors - Point detectors using scattered light, transmitted light or ionization using radio link	L-MC-SG Wireless Libra Multicriteria detector using radio link	2831-CPR-F1304
Heat detector and Smoke detectors - Point detectors using scattered light, transmitted light	ID300 Conventional multicriteria smoke (optical) and class P heat detector	0051-CPR-1873
Smoke detectors - Point detectors using scattered light, transmitted light	ID100 Conventional smoke (optical) detector	0051-CPR-1875
Heat detectors - Point detectors	ID200 Conventional class P heat detector	0051-CPR-1874
Manual call points	IC0020 Conventional Type A indoor re-settable manual call point	0051-CPR-1864
Manual call points	CW99 Conventional Type A Outdoor manual call point	2831-CPR-F2708
Manual call points using radio links	SGCP200 Wireless Type A Indoor Adressable Maunal call point using radio link	2831-CPR-F2651
Smoke detectors - Line detectors - Line detectors using an optical beam	Firebeam Xtra Line-type smoke detector	0786-CPR-20241 and DoP 0786 CPR 20241
Sounders with Short Crcuit Isolator	ES1011 Addressable ceiling sounder with SCI	0051-CPR-2036
Sounders with Short Crcuit Isolator	ES2011RE Addressable wall sounder with SCI	0051-CPR-2036
Sounders with Short Crcuit Isolator	ES2011WE Addressable wall sounder with SCI	0051-CPR-2036
Sounders with Short Crcuit Isolator	ESB1011 Addressable base sounder with SCI	0051-CPR-2036
Sounders with Short Crcuit Isolator and visual alarm	ES1021 Addressable ceiling sounder beacon with SCI	0051-CPR-2035
Sounders with Short Crcuit Isolator and visual alarm	ESB1021 Addressable base sounder beacon with SCI	0051-CPR-2035
Sounders with Short Crcuit Isolator and visual alarm	ES2021RE Addressable wall sounder beacon with short-circuit isolators	0051-CPR-2035
Sounders with Short Crcuit Isolator and visual alarm	ES2021WE Addressable wall sounder beacon with short-circuit isolators	0051-CPR-2035
Sounders	IS1011 Conventional ceiling sounder	0051-CPR-2038
Sounders	ISB1011 Conventional base sounder	0051-CPR-2038
Sounders	IS2011RE Conventional wall sounder	0051-CPR-2038
Sounders	IS2011WE Conventional wall sounder	0051-CPR-2038
Sounders with visual alarm	IS1021 Conventional ceiling sounder with visual alarm	0051-CPR-2037
Sounders with visual alarm	IS2021RE Conventional WALL sounder with visual alarm	0051-CPR-2037



Sounders with visual alarm	IS2021WE Conventional WALL sounder with visual alarm	0051-CPR-2037
Sounders with visual alarm	ISB1021 Conventional base sounder with visual alarm	0051-CPR-2037

Bilag/Annex: 2

## PRØVNINGSdokUMENTATION TEST DOKUMENTATION

<b>Akkediteret laboratorium <i>Accredited laboratory</i></b>	<b>Rapport nr <i>Report no.</i></b>	<b>Dato <i>Date</i></b>
ANPI	BFS/DE/S/044	2020-03-16
ANPI	LAB/ BFS/DE/S/044-Add1	2020-10-05
ANPI	LAB/ BFS/DE/S/044-Add2	2020-10-07
ANPI	LAB/ BFS/DE/S/044-Add3	2021-02-15

Bilag/Annex: 3

**TEKNISK DOKUMENTATION**  
**TECHNICAL DOCUMENTATION**

<b>Titel Name</b>	<b>Reference Refence</b>	<b>Dato Date</b>
Installation manual	Pravidia Bruge Manual	None
Display and operating unit With 5.7" display, Danish	Betjening ved Brand	None
Betjeningsvejledning	Pravidia-c Brugervejledning	None

Bilag/Annex: 4

## AFVIGELSER *DEVIANCE*

- The system can not be used in a hierarchical systems.